CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7320:0476:125 Page 1 of 1

CATEGORY: Speakers

LISTEE: Harrington Signal Inc., 2519 4th Avenue, Moline, IL 61265

Contact: Andrew Keller (309) 762-0731 FAX (309) 762-8215

DESIGN: Models SPA and SPL speakers. The units comprising a model number differ in voltage

and mounting configuration only. Refer to listee's data sheet for additional detailed

product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL Label.

APPROVAL: Listed as speakers for use with separately listed compatible fire alarm control units.

Separately listed visual signal appliances may be mounted on the face of either speaker

configuration (Refer to appropriate CSFM listings for strobe).

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the

appliance must be used with a fire alarm control unit that can generate the temporal pattern

signal. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7320-0811:002 (Transferred from Federal Signal Corp).



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 30, 2004 Date Issued: Listing Expires June 30, 2005

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager